



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 09/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-10A	TRIPPED OLR	RESET DONE (TRIPPING BEC OF OFF CENTERING )	01:35:00 02:30:00 04:30:00	01:45:00 02:40:00 04:40:00	
2	OHP	CO-29	TRIPPED ON OLR	RESET DONE	02:00:00	02:10:00	
3	OHP	CO-31 BRC	LT NOT MOVING	SELECTOR SWITCH IN OFF AFTER SHIFTING ... KEPT IN REMOTE	22:50:00	23:10:00	
4	CHP	CC-31 SCR-4	LT NOT WORKING	TRACK JAMMING INFORMED OPERATION	22:30:00	22:55:00	
5	CHP	CC-38 SCR-6	LT NOT WORKING	TRACK JAMMING INFORMED OPERATION	23:15:00	23:30:00	
6	CHP	CC-44	TRIPPED ON OLR	RESET DONE	00:33:00	00:40:00	
7	CHP	CC-32 R-1	BC STOPPING	YARD ZSS INTERLOCK CAGE COAL STUCK .. MADE FREE	00:45:00	01:05:00	
8	CHP	CC-40 SCR-3	BC TRIPPED ON OLR	RESET DONE	04:55:00	05:05:00	
9	CHP	CC-37 SCR-7	SLEW NOT WORKING	OIL LEVEL LOW ... IFORMED MECH	05:15:00	05:30:00	
10	CHP	SCR-5 CC-33	SLEW DOWN LIMIT BYPASS REQ FROM OPR	BYPASSED IN PROGRAM	05:00:00	05:15:00	
11	CHP	CC-51	MPD TRIPPED 15 TIMES	RESET DONE	22:30:00	06:00:00	
12	CHP	CC-38 SCR-7	LT NOT WORKING	MPCB-1 TRIPPED RESET DONE	05:45:00	06:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	OT-5	NOT MOVING	LS-2 AND LS-3 DAMAGED AND CABLE CUT DUE TO MATERIAL ... BYPASSED	01:00:00	01:30:00	
14	WT	SCO-1A	SHOWING FAULTY AFTER COMMEND	BELT SWAY BYPASSED IN PROGRAM	05:00:00	05:30:00	