



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done	00:10:00 01:15:00	00:20:00 01:25:00	
2	OHP	CO-84	OLR acted	Reset done	01:00:00	01:10:00	
3	OHP	BRC on CO-28	CT not taking place	Drive tripped.Reset done	00:30:00	00:45:00	
4	OHP	TT-1	LT not taking place	PCRD old joint opened.Rejoint done	01:00:00	01:40:00	
5	OHP	EOT crane in LOCP-1	Hoist not taking place	Checked and found electrical side okay.Brake not adjusted properly.Brake adjusted properly and tested okay	22:50:00	23:30:00	
6	CHP	CC-51	MPD tripped	Feeding conveyor stopped.Reset done	22:45:00	22:50:00	
7	CHP	CC-28	Reported tripped	OLR acted.Reset done(2 times)	05:30:00	05:45:00	
8	CHP	CC-37 SCR-3	B/C not running	OLR acted.Reset done	23:35:00	23:45:00	
9	CHP	CC-32 SCR-5	B/C not running	Wrong complaint.Yard not found running in reclaiming mode	05:10:00	05:20:00	
10	WT	OP-4	Reported tripped	Drive-1 tripped.Reset done	22:10:00	22:20:00	