



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/12/2025

Area: IOSA

Equipment	Job
BRC	HYDRAULIC POWER PACK XMD PANEL STRUCTURE WELDING DONE.
OC-2A	CHUTE VIBRATOR COUNTER WEIGHTS ADJUSTED AND CHECKED.
BRC	REMOVAL OF DAMAGED CABLES FROM TRAY AND FESTOON IS IN PROGRESS.
MISC	OM-4 TO OC-7C GALLERY CABLE LAYING IS IN PROGRESS.
WOBR (LnT)	PPM DONE ON FIELD DEVICES