



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 03/01/2026

Area: WT

Equipment	Job
CP 3	Power cable and collectors and all motor terminations removed for sending repair
OP 4	Anti collision sensor installed ,3*1.5 cu cable laid 30 mtrs, ST2 timer replaced and tested
OP 2	Anti collision sensor checked ST2 timer replaced and tested
OP 2	D3 checked ,O/L setting increased and dash pot oil replaced
OP 1,2,3,4,5,6 and 8	After rake maintenance done
MIS	LC 2A and 2B cleaning done