



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 07/01/2026

Area: OHP

Equipment	Job
tt-4	pcrd cable and position sensors inspection is done.
tt-1	pcrd cable unwinding done and proper winding done
co-9,12	motor and panel side ppm is done ; CJD ppm is done
co-12a	selector switch is replaced with spare one and kept in circuit.
rsco-1a	estop pb station checked, aux block changed and kept in circuit. belt drive motor changing is under process.