



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-10A	Reported ZSS acting	Probe adjustment done	21:30:00	22:00:00	
2	OHP	CO-50	Reported not healthy	DMPR contact not coming.Bypassed	18:00:00	18:25:00	TO be changed
3	OHP	CRusher-3A	LUB pump starting and stopping	Inner oil flow problem	21:10:00	21:20:00	Informed to mechanical
4	OHP	CO-6	Reported ZSS acting	Probe changed and tested okay	14:00:00	14:30:00	
5	OHP	CO-29	Reported tripped	OLR acted.REset done	19:20:00 20:50:00	19:30:00 21:00:00	
6	OHP	CO-12A	Reported not healthy	P/C in acted condition	19:30:00	19:50:00	INformed to operation
7	OHP	WOBR on CO-29	Luffing down not working	Solenoid supply wire got cut.Connected and tested okay	19:20:00	19:50:00	
8	OHP	BRC on CO-32	CT not moving	Chain fallen.	20:20:00	20:30:00	Informed to operation
9	OHP	Stacker on CO-21	Reported LT not taking place	LT brakes not magnetizing. Power problem.REctified	20:00:00	20:20:00	Mechanical adjustment to be done
10	OHP	WOBR on CO-6A	Reported No drives running	Checked and found PLC in stop mode.Supply and cables in RIO found okay.	20:30:00	22:00:00	Program to be checked via laptop
11	CHP	Cc-26	TT control problem	Wire connected and tested okay	18:10:00	18:15:00	
12	CHP	Cc 35 SCR-3	B/C ZSS cage struck	Bypass done for operation	15:35:00	15:55:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	Cc-37 SCR-7	SLew not working	slew chamber jamming	16:05:00	16:20:00	informed to operation
14	CHP	Cc104 scr-9	Slew not working	Tripped.Reset done	16:23:00	16:38:00	
15	CHP	Cc38 SCR-6	LT not working	Drive tripped.Reset done	16:45:00	16:55:00	
16	CHP	Cc-38 SCR-6	Signal missing	LT done and tested okay	18:15:00	18:40:00	
17	CHP	Cc-38	Reported not healthy	EM stop not properly releasing.released and tested okay	19:07:00	19:20:00	
18	CHP	Cc-38 SCR-6	interlock cage struck	Released and tested okay	21:30:00	22:00:00	
19	CHP	Cc-35	Reported tripped	OLR acted.RESET done(2times)	20:30:00 20:45:00	20:35:00 20:50:00	
20	CHP	Cc45	Reported tripped	OLR acted.RESet done	21:40:00	21:45:00	
21	WT	OT 5	Drive1,2 tripped	reset done	21:40:00	22:00:00	
22	WT	OT-3	Drive-1 tripped on Encoder fault	Reset done	21:00:00	21:10:00	
23	WT	CP-3	Reported no movement	C-clamp and U-clamp damaged at Column 61.Replaced and tested okay	15:20:00	16:20:00	