



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/07/2025

Area: CHP

Equipment	Job
SCR 10	New PLC programming job under progress
SCR 10	Cables removal job under progress
CC 48	VVVF drive panel fixed and terminations done
S 2 Repair bay	Temporary supply provided to Slew and LUFF drives, operated as mechanical required
SCR 6,S 1	Inter changed the yard machines