



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 10/12/2025

Area: IOSA

Equipment	Job
OJH-4B	HOIST MOTOR SHIFTED TO OC-7A HEAD END PLATFORM.
TIPPLER GALLERY	PPM DONE ON ELECTRICAL HOIST PANEL AND MOTOR
MOTOR VIBRATION	MOTOR VIBRATION READINGS RECORDED FOR OC-31A, OC-33A, OC-36A, OC-37A.
OC-29A	INSPECTION DONE ON FIELD DEVICES.
OC-23A	GALLERY LIGHTING CIRCUIT DEFECTS RECTIFIED. LIGHT FITTINGS TO BE PROVIDED.