RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 06/08/2025

Area: CHP

Equipment	Job
CC 41,46,107,112,125,126,SCR 2,8,9,S1	RUNNING INSPECTION WAS DONE
SCR 10	Boom conveyor motor coupling fixed and made ready
CC 43/44	3 nos 35W lamp fixtures replaced and improved lighting
CC 42,VS3,VF3,130,131,131TT	PPM WAS DONE
SCR 10	Cable dressing done. Slew,luff limits ,LT end limit kept in ckt.