



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 28/06/2025

Area: IOSA

Equipment	Job
OC-2A and OC-3A	LIGHT PROVIDED OC-1A TO OC-2A CHUTE AND OC-2A TO OC-3A CHUTE FOR MECH JOB
OC-9A and OC-11A	PPM DONE ON PANEL SIDE.
1-14LBDS BLDG	HOUSEKEEPING DONE FOR STAIRCASE
OC-27A and OC-29A	MOTOR VIBRATION RECORDED.
OC-14A	110V FROM PLC AND 110V FROM MCC PANEL DISCONNECTED IN CJB.