



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 1A	BRS bypass request	bypassed in CJB	21:00:00	21:10:00	
2	OHP	RSCO 10A	CO 15 placement indication missing	wire checked and tightened near switch, CJB .	16:25:00	16:45:00	
3	OHP	co-77	brs kept in ckt as per opr req	done	21:30:00	22:00:00	
4	CHP	CC 105 , SCR 7	Slew not working	Charge pressure alarm . Spider reset	14:50:00	15:15:00	
5	CHP	CC 39	Emergency PB acted	released , then healthy	17:10:00	17:20:00	
6	CHP	CC 39 , SCR 6	BW not running	Oil level low. Informed to mechanical. After mechanical request , oil level low bypassed	18:00:00	20:00:00	Bypassed in system
7	CHP	CC 54	OLR acted ( 3 times)	reset done	19:00:00	19:30:00	
8	CHP	CC 113	Stopped due to CC 52 overload acted	reset done	20:20:00	20:25:00	
9	CHP	CC 26	Flap gate MPCB tripped	reset done	16:45:00	16:55:00	
10	CHP	CC 102	BRS bypassed on operation request	again kept in circuit	17:40:00	17:50:00	