



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 08/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------|---|--|----------|----------|----------|
| 1 | OHP | CO7a | reported no drives running found ACB tripped | ACB made on | 17:40:00 | 18:00:00 | |
| 2 | OHP | CO32a | BRS kept in ckt | in ckt patch work done and mechanical dept requested | 21:10:00 | 21:10:00 | |
| 3 | CHP | CC 41 | cjd acted, bypass cable loose in i/o rack | cable tightened than healthy | 19:00:00 | 19:10:00 | |
| 4 | CHP | CC 38 SCR 6 | b/c not running, signal missing, for all conveyor | power recycle done in CCR micro plc | 19:10:00 | 19:35:00 | |
| 5 | CHP | CC 33 SCR4 | LT not working | wrong complaint, informed operation | 19:50:00 | 20:00:00 | |
| 6 | CHP | CC51 | over load tripped 2 times due to over load (feeding conveyor stopped) | Reset done | 18:10:00 | 18:20:00 | |
| 7 | CHP | CC114 | over load tripped | Reset done | 18:40:00 | 18:50:00 | |
| 8 | WT | CC3 Belt | Over load Tripped | Reset done | 17:25:00 | 17:30:00 | |
| 9 | WT | SCO1A | R phase lug damaged | Replaced | 17:30:00 | 17:30:00 | No delay |
| 10 | WT | CT2 Inhaul | olr tripped | Reset done | 18:30:00 | 18:40:00 | |