



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-20	LT M-1 TRIPPED	RESET DONE	17:45:00	18:00:00	
2	OHP	CO-48	NOT HEALTHY ... ADD.ONBLOCK LOOSE	FIXED PROPERLY	15:15:00	15:30:00	
3	OHP	TT-3 ON CO-22	POSITION SIGNAL NOT COMING .. SENSOR PROBLEM	BYPASSED IN SYSTEM	19:30:00	19:45:00	
4	CHP	CC-33 SCR-5	LT NOT WORKING MPCP-5 TRIPPED	RESET DONE	15:15:00	15:30:00	
5	CHP	HOIST CC-126	UP CONTACTOR PROBLEM	CHANGED	15:30:00	16:30:00	
6	CHP	CC-104 SCR-9	ACB TRIPPED	MADE ON	19:15:00	19:30:00	
7	CHP	CC-51	TRIPPED IN OLR (2 TIMES)	RESET DONE	19:40:00	19:55:00	
8	WT	OT-5	DRIVES TRIPPED	RESET DONE	18:15:00 21:05:00	18:17:00 21:07:00	
9	WT	OP-7	ACB TRIPPED IN LC -2A	MADE ON	18:50:00	19:00:00	
10	WT	OP-3	ACB TRIPPED IN LC-2B	MADE ON	19:45:00	19:55:00	
11	WT	OP-5	NOT MOVING	EMG STOP RELEASED	20:30:00	20:40:00	
12	WT	OT-4	D1 TRIPPED ON PGF FAULT	RESET DONE	20:55:00	21:00:00	