



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/05/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO26	DRIVES ARE NOT RUNNING LOWER LIMIT ACTED	RELEASED THAN OK	17:30:00	17:45:00	
2	OHP	TBS ON CO 22	LT NOT TAKING PLACE PCRD GUIDE PROBLEM	INFORMED TO MECH	20:50:00	21:10:00	
3	CHP	CC125	OLR ACTED	RESET	16:45:00	16:50:00	
4	CHP	CC44	OLR ACTED	RESET	18:15:00	18:20:00	
5	CHP	CC35 SCR 2	LUFFING PUMP NOT RUNNING OIL HIGH TEMP ACTED	BY PASSED AFTER OIL COOLING BYPASS REMOVED THAN OK	18:05:00	18:20:00	