



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/11/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	olr acted	reset	22:30:00	22:36:00	
2	OHP	CO 33M	over current fault	reset	23:00:00	23:05:00	2 times
3	OHP	BRC on co 30	bc olr acted	reset	02:15:00	02:30:00	
4	OHP	VF1A	olr acted	reset	01:30:00	01:35:00	
5	CHP	CC 131	olr acted	reset	03:00:00	04:15:00	2 times
6	CHP	CC 35 scr3	bc olr acted	reset	23:30:00	23:45:00	
7	CHP	cc 33 scr 5	pcrd cable zig zag	pcrd cable unwinding and winding done	05:40:00	06:00:00	informed mechanical