



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|---|----------------------|----------------------|---|
| 1 | OHP | CO-36 | Reported BRS not getting reset | Checked and found BRS healthy and acting fine.Reset done | 10:00:00 | 10:15:00 | |
| 2 | OHP | CO-29 | Reported emergency acted even though released | Checked and found fuse burnt in CJB.P/C earth fault.P/C bypassed,field wires removed in CJB and tested okay | 08:10:00 | 08:30:00 | P/C to be checked and to be kept in line |
| 3 | OHP | WOBR on CO-26 | Reported no drives running | Checked and found slew right emergency acted. Slewing done bypassing and control made on and operations tested okay | 10:15:00 | 10:30:00 | SLew right limit switch to be checked |
| 4 | OHP | WOBR on CO-25 | HT cable joint pending from C-shift | DNW did cable joint and power restored and operations tested okay | 06:00:00 | 09:00:00 | |
| 5 | OHP | CO-12(C/D) | Reported tripped | OLR acted.Reset done | 09:20:00 | 09:30:00 | |
| 6 | OHP | RSCO-10A(C/D) | Reported Tripped | OLR acted.Reset done | 10:15:00 | 10:30:00 | |
| 7 | CHP | CC-54 | Reported tripped | OLR acted.Reset done(2 times) | 09:45:00 11:15:00 | 09:55:00 11:25:00 | |
| 8 | CHP | CC-131 | Reported tripped | OLR acted.Reset done | 07:35:00 | 07:40:00 | |
| 9 | CHP | CC-112 SCR-8 | Reported B/C signal missing and LT not moving | modem power recycled and Lt end limit bypassed and tested okay | 06:35:00 | 07:15:00 | Operation request given for Lt end limit bypass |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2025

Shift: A

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--------------------------|--|----------------------|----------------------|---------|
| 10 | CHP | CC-112 SCR-8 | Luffing not working | Oil level low.informed to mechanical | 07:40:00 | 07:50:00 | |
| 11 | CHP | CC-31 SCR-4 | Reported B/W not running | Charge pressure acting frequently.Informed to mechanical | 09:30:00 | 09:45:00 | |
| 12 | CHP | CC-38 SCR-6 | TUL C/S acted | Bypassed due to rain as per operation request | 12:00:00 | 12:10:00 | |
| 13 | WT | OT-1 | Drive-1 tripped | PGEF fault.Reset done(2 times) | 10:15:00 12:00:00 | 10:20:00 12:10:00 | |