



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/09/2025

Incharge(s): V Balaji Naik

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO29	olr	reset done	06:05:00 08:30:00	06:10:00 08:35:00	
2	OHP	CO26	olr trip	Reset done	06:10:00	06:15:00	
3	OHP	BRC on CO32	CT not working CT chain came out	Informed to mechanical and operation	08:10:00	08:20:00	
4	OHP	BRC on CO33M	BW 1 not working stone struck in ZSS	Removed	09:30:00	09:45:00	
5	OHP	Stacker CO21	chute sensor acting due lake of rubber liners	Reset done	13:30:00	13:40:00	
6	CHP	CC26	Flap gate MPCB trip	Made on	09:23:00	09:35:00	
7	CHP	OC1a	ZSS acted due to material jaming	Informed to operation	10:00:00	10:00:00	
8	CHP	CC51	MPD over load trip feeding conveyor stop 5 times	Reset done	06:50:00	06:55:00	
9	CHP	SCR3 onCC40	LT not working drive olr over load trip	Reset done	07:10:00	07:20:00	
10	CHP	SCR7 onCC37	LT not working m5 AND m6 TRIP	mpcb MADE ON	08:35:00	08:45:00	
11	CHP	cC125	OLR TRIP	Reset done	09:35:00	09:45:00	
12	CHP	SCR7 onCC37	BC not running CJB1 2 common not coming	spare core changed	09:00:00	09:20:00	
13	CHP	SCR10 on CC105	chute sensor acted	Reset done cleaned	12:30:00	12:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/09/2025

Incharge(s): V Balaji Naik

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	SCR1 on CC36	Position bit not coming	Position bit bypassed GVM	12:50:00	13:00:00	
15	CHP	CC44	motor olr trip	Reset done	10:00:00	10:10:00	
16	CHP	CC39	olr trip	Reset done	10:50:00	10:55:00	
17	CHP	SCR7 on CC37	Slew not working right side limit acted	Limit bypass due to coal jamming informed to operation	09:45:00	09:55:00	