



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 30/07/2025

Area: WT

Equipment	Job
CO 2 level	Lighting,circuit problem rectified
OP 1	D4motor slip rings found damaged, buffing and cleaning done ,Brush holders with brushes replaced
OP 1,8 and CP 1	after rake maintenance done
LC 1	Lighting improved,3 nos LED Tubes replaced@ AF Panels