



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/08/2025

Shift: C

Incharge(s): V Balaji Naik,Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT 4 on co 22	bit missing,wire loose in sensor	wire tightened	04:00:00	04:10:00	
2	OHP	WOBR on co 29	luffing not working,up limit acted	luff down than ok	04:40:00	04:50:00	
3	OHP	BRC on co 31	b/c not running,olr acted and belt problem and material jammed	olr reset,and direction changed as per operation request	01:00:00	01:20:00	
4	OHP	tbs on co 20	signal missing,NO contact in contactor loose connection	tightened,CS bypassed in program,cs relay in rmu panel used for boom running signal latching	23:30:00	00:30:00	to be normalised
5	OHP	TT2	double indication in CO21 and CO19	ab	05:45:00	06:00:00	Conveyor also running further check is required
6	CHP	CC 51	mPD tripped in olr	reset it done	05:15:00	05:20:00	
7	CHP	SCR 6 ON cc 38	slew not working,jamming	informed operation	22:10:00	22:20:00	
8	CHP	SCR 10 on CC 105	b/c not running,olr acted ,b/c stopped push button problem stucked	reset,released PB	01:00:00	01:20:00	
9	CHP	SCR 10 on CC 105	b/w not working,mccb tripped	made it on	03:00:00	03:10:00	
10	CHP	SCR 3 on CC 40	b/c stopping	wrong complaint	05:15:00	05:25:00	
11	CHP	CC 14	OLR acted	reset	22:30:00	22:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	OT4	D1 trips in pgf4 fault	reset	23:00:00	23:02:00	
13	WT	OT 4	D2 trips in pgf1 fault	reset	01:40:00	01:41:00	
14	WT	OAF 2	no movement, full jamming, mech problem	kept in local cleaning done than ok	01:30:00	01:35:00	