



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/01/2026

Area: OHP

| Equipment   | Job  |
|---|--|
| om-15,16,24   | mcc rooms house keeping is done.                                     |
| losp-2 ; co-10a, rsco-1a, rco-6a, bf-3a, 4a, 5a, vf-1a, 2a, vs-1, 2a, 3a, 4a, 5a , bf-1a , 2a, 7a, 8a, 9a | motor and panel side ppm is done                                     |
| co-7 pullchord  | earth fault is rectified, to be kept in circuit when conveyor stops. |
| brc-2 shifting  | shifted from repair bay to co-30                                     |
| brc-1 shifting  | shifted from co-30 to co-8a  |
| For brc-1 on co-30 b/w-1  | spare motor trail run is taken at hvmmcc-1                           |
| co-58   | motor and panel side ppm is done.                                    |