



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/06/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 9	ELECTRONIC OLR ACTED (3TIMES)	RESET	17:30:00	21:00:00	
2	CHP	CC 131	OLR ACTED (2TIMES)	RESET	16:45:00	17:30:00	
3	CHP	CC 132	OLR ACTED	RESET	19:50:00	20:00:00	
4	CHP	CC 32 SCR 5	LT NOT TAKING PLACE E/STOP ACTED	RELEASED AND POWER RECYCLED THAN OK	14:30:00	14:40:00	
5	CHP	CC 111 S3	LUFFING NOT TAKING PLACE MCCB TRIP	MADE ON	14:45:00	15:00:00	DUE TO OIL LEAKAGE INFORMED TO MECH
6	CHP	CC 35 SCR2	LT NOT WORKING O/T ACTED	RELESED	17:00:00	17:20:00	
7	CHP	CC 32 SCR5	LT NOT WORKING O/T ACTED	RELEASED	18:00:00	18:20:00	
8	CHP	CC35	D/E SIDE C/S NOT WORKING PROBE CABLE CUT	MODULE TO PROBE NEW CABLE REPLACED THAN OK	18:35:00	19:05:00	
9	CHP	CC 111 S3	SIGNAL MISSING (2TIMES)	LT FORWARD MOVES SIGNAL THAN HEALTHY	19:30:00	21:25:00	
10	WT	OT 3	D 1 TRIP	RESET	19:45:00	19:50:00	