



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 24/12/2025

Area: IOSA

Equipment	Job
MISC	OM-4 TO OC-7C CABLE LAYED IN CABLE TRENCH UP TO PDB IN OM-4 FROM OC-7C MIDDLE POWER SOCKET
WOBR-LnT	POWER RESTORED FOR MACHINE AND TRIAL RUN TAKEN. RMU SIGNAL CHECKED AND HMI FEEDBACK CHECKED.
TBS	RMU SIGNAL CHECKING DONE AT OC-11A AND LC-2 PLC.
OC-13A	PPM DONE ON FIELD DEVICES