



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 10/12/2025

Area: OHP

Equipment	Job
TIS-2	motor meggered along with cable trail run taken, current is balanced (4A) and restored in circuit after trail run is complete.