



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/07/2025

Area: WT

Equipment	Job
OP 9	Modification for drive bypass and drive in circuit option provided in SCADA
CT 1	Hooper area one no 200W LED replaced and 2 nos Tubes replaced in coal scooter shed
OT 5	New 'SICK' Anti collision device installed at out haul side wagon sensor for testing purpose
OP 2	panel and motor side ppm done ,D5 OLR replaced and kept in circuit
OP4 and 6	after rake maintenance done