



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/07/2025

Area: WT

Equipment	Job
OP 3	Anti collision device new unit installed and testing done, OK
EOT Crane(C)	Main Host ,I/C cable lug 1 no replaced
OT 2 series	Motor side ppm done
OP 1,4 and 6	after rake maintenance done