



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/07/2025

Shift: B

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------------|--|--|----------------------|----------------------|-------------------------------|
| 1 | OHP | 1-14 LC7 and 1-14 LC 8 | PANEL NO. 29 FEEDER 2 CLEARANCE GIVEN FROM DNW | H.T BREAKER MADE ON AT 1-12 LBDS 4 and 5 | 16:00:00 | 16:12:00 | |
| 2 | OHP | co 29 | tripped on olr | reset done | 18:45:00 | 18:55:00 | |
| 3 | OHP | co 35 | tripped on olr | reset done | 18:40:00 | 18:50:00 | |
| 4 | OHP | tt 4 on bypass 2 | chute position signal not getting to ocr | temporary bypassed | 19:45:00 | 20:15:00 | |
| 5 | OHP | co29 | reported red /glass fuse blown at cjb due to earth fault in pullcard | field wires removed and kept bypass at cjb | 21:10:00 | 21:25:00 | to be kept in ckt |
| 6 | OHP | co 29 | operation request brs bypass | bypass done | 17:15:00 | 17:30:00 | |
| 7 | CHP | scr 2 on cc34 | slew not taking place/wrong complaint | tested ok | 16:40:00 | 16:50:00 | |
| 8 | CHP | R1 ON CC31 | bc signal missing/ | plc recycled then ok | 18:35:00 | 18:50:00 | now working on zss inter lock |
| 9 | CHP | cc 117 | tripped on olr | reset done | 15:20:00 20:15:00 | 15:35:00 20:30:00 | |
| 10 | CHP | cc 54 | tripped on olr 2 times | reset done | 17:35:00 18:10:00 | 17:40:00 18:15:00 | |
| 11 | CHP | vs 3 | tripped on olr 2 times | reset done | 21:05:00 | 21:10:00 | |
| 12 | CHP | cc 40 | brs acting frequently due to offcentring | inform to operation | 16:10:00 | 16:20:00 | |
| 13 | CHP | scr 5 on cc32 | It not taking place/vfd drive fault on ovr | reset done | 17:05:00 | 17:15:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/07/2025

Incharge(s): G Eswara Rao

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|----------------|------------|----------|----------|---------|
| 14 | WT | cc 2 C/D | tripped on olr | reset done | 16:30:00 | 16:40:00 | |