



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/01/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------|--------------------------|-----------------|----------------------|----------------------|---------|
| 1 | OHP | CO 34 | OLR ACTED | RESET | 08:40:00 | 08:45:00 | |
| 2 | OHP | CO 84 | OLR ACTED | RESET | 10:30:00 | 10:45:00 | |
| 3 | OHP | CO 11 CD | OLR ACTED | RESET | 07:25:00 | 07:30:00 | |
| 4 | OHP | CO 12 | OLR ACTED | RESET | 07:20:00 | 07:25:00 | |
| 5 | CHP | SCR 10 ON CC 105 | LT PCRD O/T ACTED | RELEASED | 08:30:00 | 08:45:00 | |
| 6 | CHP | S 3 ON CC 111 | OLD JOINT GOT FAILED | INFORMED TO DNW | 11:45:00 | 12:00:00 | |
| 7 | CHP | CC 51 A | OLR ACTED | RESET | 10:55:00 | 12:00:00 | 5 TIMES |
| 8 | CHP | CC 117 | OLR ACTED | RESET | 07:45:00 | 08:00:00 | |
| 9 | CHP | CC 114 | OLR ACTED | RESET | 10:10:00 13:30:00 | 10:20:00 13:35:00 | |
| 10 | WT | OT 4 | D2 TRIPPED | RESET | 10:30:00 | 10:35:00 | |
| 11 | WT | OT 2 | D2 TRIPPED ON PGF1 FAULT | RESET | 13:20:00 | 13:25:00 | |