



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/09/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 77	MCCB R PHASE GOT FAILURE	CO 83 MCCB REMOVED AND REPLACED	00:00:00	00:30:00	NEW MCCB LM 200 HAS TO BE PROVIDED FOR CO 83
2	OHP	BRC ON CO 32	B/C OLR ACTED	RESET	04:00:00 05:20:00	04:15:00 05:40:00	
3	OHP	CO 29	SLEW DRIVE TRIPPED	RESET	04:30:00	04:50:00	
4	OHP	CO 49	BRS NOT RESETTING	BYPASSED	05:50:00	06:00:00	
5	OHP	VS2	OLR ACTED	RESET	02:00:00	02:10:00	
6	CHP	SCR 7 ON CC 37 SLEW	CHARGE PRESSURE ACTED	RESET	23:20:00	23:45:00	
7	CHP	SCR 1 ON CC 36	LT DRIVE TRIPPED	RESET	00:50:00	01:10:00	
8	CHP	SCR 3 ON CC 40	B/C SIGNAL MISSING	LT DONE TOWARDS DRIVE END THEN OK	03:20:00	03:40:00	
9	CHP	CC 27A	TRIPPER POSITION SENSOR	BYPASSED ON CO 39	23:10:00	23:20:00	SENSOR A ALIGNMENT TO BE DONE PROPERLY
10	CHP	CC 54	OLR ACTED	RESET	04:50:00	05:30:00	
11	CHP	CC 51	OLR FEEDING CONVEYOR ACTED	RESET	00:00:00	05:30:00	9 TIMES



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/09/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	OT5	VERTICAL CLAMPING FUSE BLOWN DUE TO WATER IN LS 3	FUSE REPLACED	01:55:00	02:00:00	
13	IOSA	TBS ON OC 13A	RBC STOPPING FREQUENTLY DUE TO BS AND OFF CENTERING	INFORMED TO MECH	00:30:00	00:50:00	