



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/08/2025

Area: WT

Equipment	Job
CP 3	D2 motor changing and testing done with New motor ,stator cantactor kit replacd
OP 4 and 6	After rake maintenance done