



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/09/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT2	CHUTE VIBRATOR	MOTOR BURNT	17:10:00	17:30:00	
2	OHP	CO 26 WBR	LUFF 24V FUSE BLOWN	REPLACED	15:45:00	16:00:00	
3	OHP	CO 13(C/D)	CARRIAGE DRIVE MPCB TRIPPED	MADE IT ON	21:40:00	21:50:00	
4	OHP	TBS ON CO 7A	BRAKE MPCB TRIPPED	MADE IT ON	21:30:00	21:45:00	
5	OHP	BRC on CO-30	Reported yard interlock not working	Checked and found probe damaged.Probe replaced and tested okay	18:00:00	18:30:00	
6	OHP	BRC ON CO-30	Reported B/W-1 not rotating	Checked and found command not coming to xmd panel.Wire checked and rectified.	18:30:00	19:00:00	
7	OHP	BRC on CO-30	Reported B/W-1 not rotating	Checked and found fuse tb problem.Fuse tb replaced and tested okay	22:00:00	22:30:00	
8	OHP	BRC on CO-34	Reported LT not taking place	Guide problem.Informed to mechanical	18:00:00	18:20:00	Loop given for reclaiming
9	OHP	VS-2	Reported tripped	OLR acted.Reset done	18:15:00	18:20:00	
10	OHP	BRC on CO-30	Reported LT not taking place	Checked and found skew limit acted.Skew adjustment done and LT tested okay	21:45:00	22:00:00	
11	CHP	CC 51	MPD TRIPPED	RESET	15:20:00	15:30:00	
12	CHP	S1 ON CC 39	LT POTENTIOMETER	REPLACED	16:25:00	16:55:00	
13	CHP	SCR 3 ON CC 40	LUFF OLR ACTED	RESET	15:45:00	16:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/09/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	SCR 3 ON CC 40	SLEW OIL LEVEL LOW	INFORMED TO MECH	20:20:00	20:30:00	
15	CHP	CC 203	CC 28 RUNNING SIGNAL NOT COMING	COMMUNICATION PROBLEM CHECKING UNDER PROGRESS	21:20:00	22:00:00	
16	CHP	CC-51	tripped	MPD tripped. Reset done	15:20:00	15:25:00	
17	WT	CP1	COMMUNICATION FAULT	POWER RECYCLED	18:00:00	18:20:00	
18	WT	OP-6	Pusher forward and reverse not taking place	LC-2B I/C-1 tripped.Made on and tested okay	18:00:00	18:30:00	