



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 28/01/2026

Area: OHP

Equipment	Job
cr-1,2,3	ht fuse healthy contact is taken to io rack as "panel healthy" bit and kept in circuit.
wobr-1 on repair bay	testing job, dressing and old cables removal is under progress.
CO-78,85,87	MOTOR AND PANEL SIDE ppm is done