



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/11/2025

Area: WT

Equipment	Job
CP 3	Trolly line inspection done ,track sink points noted and informed Traffic/Railways
LC 1 and 9	All panel doors inspected and closed
OP 9	Panel and Motor side ppm done
OP 3 and 1	After rake maintenance done, OP 1 found bottom C clamp bent ,replaced it
MIS	coal tippler walk way Bridge area lighting contactor and one MCB 10A replaced