



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|---|----------|----------|--------------------------------|
| 1 | OHP | CO 26 | olr acted | reset | 23:35:00 | 23:45:00 | 3 |
| 2 | OHP | BRC 31 | LT not taking | wrong complaint | 00:00:00 | 00:30:00 | |
| 3 | OHP | WOBR 25 | slew not working, drive trips in overload | reset | 01:10:00 | 01:20:00 | |
| 4 | OHP | WOBR 26 | slew not taking place, drive trips in overload | reset | 03:05:00 | 03:20:00 | |
| 5 | OHP | WOBR 26 | b/w not running, zss cage stucked | cage released | 04:44:00 | 05:00:00 | |
| 6 | OHP | CO 29 | olr acted | reset | 05:40:00 | 05:45:00 | |
| 7 | OHP | CO 16 | not healthy, MPD parameter goes to initial state, operation kept in local and run many number of times | U mpd relay parameter reset | 05:00:00 | 05:40:00 | |
| 8 | CHP | CC 35 SCR2 | LT not taking place M2mpcb trips | made it on | 23:00:00 | 23:10:00 | |
| 9 | CHP | CC 223 | not running, cjs acted, after that found all healthy but power contactor C1 not picked up | replaced contactor with CC 214 spare | 02:00:00 | 02:20:00 | |
| 10 | CHP | CC 112 scr 8 | left side slew not working, slew limit acted | wrong complain | 01:30:00 | 01:40:00 | |
| 11 | CHP | CC 131 | overload acted | reset | 01:40:00 | 01:45:00 | |
| 12 | CHP | CC 31 | ZSS acted, zss cage lifted by mech | cage released | 05:20:00 | 05:25:00 | |
| 13 | CHP | CC 38 SCR3 | b/c not running, signal missing | ethernet cable unplug plug, modem power recycle than ok | 05:00:00 | 05:30:00 | |
| 14 | WT | OP9 | no movement, communication problem | run in local than remote | 22:15:00 | 22:30:00 | no delay after rack completion |