



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/06/2025

Area: OHP

Equipment	Job
cr-1	oil flow fault is pending, Oil flow switch needs to be checked along with instrumentation. ,
BRC-1	shifted from co-30 to co-8a