



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 31/05/2025

Area: OHP

Equipment	Job
losp-1 and locp-1	sb levels ppm is done.
JH O-3 hoist	hoist motor supply problem is rectified, load trail is done, brake is not acting properly, mechanical is informed.
running inspection	running inspection of co-77 and co-29 , brc-1 and brc-3 is done
tbs-3 shifting	shifted form co-7a to 21
tbs-1 shifting	shifted from co-21 to 7a
tbs on co-24	ppm is done
hoists ppm	co-59 ,bpc-1, bpc-2, 27a,30a,31a,33a,35a,37a,38b,65 h/e hoists ppm is done