



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/11/2025

Area: IOSA

Equipment	Job
OC-18A	PPM DONE ON FIELD DEVICES.
BLENDER RECLAIMER	BUCKET WHEEL-2 ZSS SENSOR FIXING PLATE GOT DAMAGED. REPLACED WITH ANOTHER FIXING PLATE, FIXED SENSOR AND TRIAL RUN TAKEN.
BLENDER RECLAIMER	ONE THRUSTER BRAKE PROVIDED AT MOTOR-8 POSITION. TRIAL RUN TAKEN.
TBS	LEFT AND RIGHT BOOM VFD PARAMETERS CHECKED .
OC-21A	LIGHTING DEFECTS RECTIFIED AND PROVIDED ONE 200W LED LAMP FITTING IN TUNNEL
OTT-1A	POWER CABLE DRESSING DONE.
OC-16A	MECHANICAL TYPE BRS FIXED. MODULE TO BE MADE AND FIXED.
THRUSTER BRAKES	CHECKED AFTER CLEANING. ONLY ONE IS WORKING
OC-21A	BRS REMOVED AND SHIFTED TO ELECT. SHED. TO BE CHECKED.