



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/02/2026

Area: OHP

Equipment	Job
om 10 to om-24 control supply	cable for io rack control supply is traced, checked and charged. to be connected at om24 io rack.
co-3b; co-66,69	motor and panel side ppm is done.
co-8 pullchord	checked and kept in circuit.
co-3a	spare core from brs point to io rack is identified for mechanical brs and is brought to io,, to be programmed in circuit.
co-12a h/e hoist	ppm is done
co-10a,rco-6a,rsc0-1a, vf-1a,2a, bf-3a,4a,5a ; rsc0-2a,rbf-1a,2a,3a	motor side ppm is done
co-11a gallery	lighting and sockets supply separation is under process.
rsc0-1a spare motor	received from ers at lc7