



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/05/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on Co 19	Left luff not taking place, olr acted	olr reset	07:30:00	08:00:00	brake problem of mechanical
2	OHP	TBS on CO 19	left luff not taking place, control not through mccb ad on block	add on block replaced	09:00:00	09:30:00	
3	OHP	CO 33M	olr acted	reset it done	11:45:00	11:55:00	
4	OHP	BRC on CO 33 M	b/c not running, e stop acted	released	09:50:00	10:00:00	
5	OHP	BRC on CO 32	BW1 not running, olr acted	reset it done	09:50:00	10:10:00	
6	OHP	TBS on co 7a	LT not taking place, m3 olr acted	reset	09:30:00	09:45:00	due to track jamming
7	OHP	CR 1A	trip in vibration	reset	10:00:00	10:15:00	
8	OHP	RSCO 1A to SB 4A	position indication problem, toggle switch problem	bypass near cjb	11:20:00	11:40:00	switch to be changed
9	CHP	CC 34 SCR2	LT not taking place, OT acted	OT released	08:00:00	08:10:00	
10	CHP	CC 31 S3	B/c not running, mpd trips due to OLR	mpd reset	08:30:00	08:40:00	
11	CHP	CC 52	stopping in ZSS fault, ZSS ok,	changed VFD to DOL mode again kept in VFD mode	09:30:00	09:40:00	
12	CHP	CC 54	OLR acted	reset	08:50:00	08:55:00	
13	CHP	CC 131	OLr acted	reset it done	11:35:00	11:40:00	2 times