



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/12/2025

Area: OHP

Equipment	Job
provision of 3-phase supply at chute 1 of co-35	job is under process.
co-15a,41a,42a,43a h/e hoists	hoists ppm is done
1-14LC8 incomer 2	made on and bus coupler is kept off.
co-70, 60,63 ; tbs-7 on co-19 ; co-36b motor side	motor and panel side ppm is done.
TIS-2 motor	3C*2.5sqmm cable laying is done along the new tray from 1-14lc3 to cf-1 flap gate area , termination needs to be done at both ends.
EOT-2	main hoist was not working, Command glass relay was not making properly, replaced with normal aux. relay and tested hoist operations.