



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/10/2025

Area: CHP

Equipment	Job
70W SV fixtures	6 nos fixtures made ready for use
SCR 1	New PLC panel side control wiring completed and control JB wiring under progress
CC 212/213	ZSS ans CJS checked and found in ckt
CC 215,216,217,218,220,221,222	PPM was done
Stacker 3	Shifted from CC 213 to CC 111