



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/02/2026

Area: OHP

Equipment	Job
brc-2 on co-31	shifted to co-30
lbds-6 io rack	one sitop of io rack is powered with 230v as alternate source, taken from ACDB in LBDS-6.