



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/12/2025

Area: IOSA

Equipment	Job
OC-7A	HOIST BRAKE PANEL WIRING DONE AND TESTED AFTER RECTIFYING BRAKE JAMMING.
OC-2A	LIGHTING PROVIDED NEAR T./E FOR MATERIAL CLEANING.
OC-21A AND OC-23A	HT MOTOR TEMPERATURES AND MOTOR VIBRATIONS CHECKED AND RECORDED.
OC-6A	FIELD DEVICES FEEDBACK IN HMI AND PLC CHECKED.
OC-5A	FIELD DEVICES FEEDBACK IN HMI AND PLC CHECKED
OC-4A	FIELD DEVICES FEEDBACK (IN HMI and PLC) CHECKING DONE.
TBS	HT CABLE LOOP GIVEN DUE TO PCRD CHAIN GUIDE PROBLEM.
OC-6A	LIGHTING CIRCUIT DEFECTS RECTIFIED AND SUFFICIENT LIGHTING ARRANGED.
BLENDER RECLAIMER	PCRD RESISTANCE PANEL MAINTENANCE DONE. REPLACED RUSTED TERMINAL BOLTS.
OC-27A	RUN IN LOCAL MODE AND CURRENT VALUES RECORDED.
OC-7B	PPM DONE ON FIELD DEVICES OF OC-7B CONVEYOR (ZONE-2,3)