



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/02/2026

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-8	Reported BRS not healthy	Checked and found BRS reset button stuck up.Made free and both BRS checked and kept in line.	23:30:00	23:45:00	P/C bypassed at MCC panel as per operation request
2	OHP	CO-5A	Reported BRS acting frequently	Checked and found BRS to be okay but found belt offcentered in between around 40 metres	23:40:00	00:00:00	
3	OHP	CO-26	Reported tripped	OLR acted.Reset done	00:25:00	00:35:00	
4	OHP	CO-36	Tripped	OLR acted.Reset done	01:00:00	01:10:00	
5	OHP	WOBR on CO-29	Reported B/W not rotating	Checked and found motor burnt.	02:45:00	04:00:00	Motor to be replaced
6	OHP	WOBR on CO-25	LT not taking place	Drive tripped.Reset done	04:00:00	04:15:00	
7	OHP	CO-36	Reported tripped	OLR acted.Reset done	01:10:00	01:15:00	
8	CHP	CC-51	MPD tripped	Reset done	00:50:00	00:55:00	
9	CHP	CC-54	Reported tripped	OLR acted.Reset done	01:20:00	01:25:00	
10	CHP	CC 104 SCR-7	LT not taking place	Drive tripped.Reset done	23:30:00	23:38:00	
11	CHP	CC-104 SCR-7	BC not running	TUL chute jamming found.	23:40:00	23:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/02/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 105 SCR-10	Reported no operations taking place	Checked and found one fuse blown at I/O.Coupler opened and found machine side one core problem	03:10:00	05:50:00	Informed to general shift incharge
13	CHP	CC-213	Reported tripped	OLR acted.Reset done	04:30:00	04:40:00	
14	CHP	CC 108	Reported tripped	OLR acted.Reset done	05:20:00	05:25:00	