



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/05/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO23	BRS NOT RESETTING	BY PASSED	08:20:00	08:35:00	
2	OHP	CO33M	OLR ACTED	RESET	08:30:00 10:30:00	08:40:00 10:45:00	
3	OHP	BRC ON CO32	B/C NOT RUNNING OLR ACTED	RESET	09:00:00	09:45:00	DUE TO JAMMING
4	OHP	TBS ON CO20	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	10:00:00	10:15:00	
5	OHP	WOBR ON CO25	B/C NOT RUNNING ZS CAGE STUCK WITH STONE	STONE REMOVED THAN OK	12:15:00	12:35:00	
6	CHP	CC54	OLR ACTED	RESET	10:15:00	10:30:00	
7	CHP	CC40	OLR ACTED	RESET	11:00:00	11:10:00	
8	CHP	CC 34 S1	SLEWING NOT WORKING DUE TO JAMMING	INFORMED TO OPERATION	11:30:00	11:50:00	
9	CHP	CC 34 SCR 5	B/C NOT RUNNING MCCB TRIPPED	MADE ON	12:00:00	12:20:00	
10	CHP	CC31 S3	LT NOT TAKING PLACE U/T LIMIT ACTED	RELEASED THAN OK	12:25:00 13:30:00	12:45:00 13:45:00	
11	CHP	CC31	BRS	BY PASSED OPERATION REQUIREMENT	13:40:00	13:50:00	
12	CHP	CC 39 SCR 7	LT NOT TAKING PLACE CHECKED NO PROBLEM	FAULT RESET THAN OK	07:10:00	07:35:00	
13	WT	OT 4	LIMIT SWITCH CABLE GOT CUT	JOINT DONE	11:15:00	11:25:00	