



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/06/2025

Area: WT

Equipment	Job
MIS	Ore and Coal Tunnel Exhaust Fans,checked and kept on running
MIS	Ore side dead end lighting checked found 3 pole MCB trip,made it ON and circuit problem rectified
CT 1 and 2 series	panel and motor side ppm done
OP 1,3,8 and CP3	after rake maintenance done