



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/12/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-26	Slew not moving	Drive tripped.Reset done	22:35:00	22:50:00	
2	OHP	CO-6	ZSS acted	Probe problem.Probe replaced and tested okay	22:30:00	22:50:00	
3	OHP	CO-25	Reported tripped	OLR acted(2 times)	01:30:00	01:40:00	
4	OHP	CO-84	Reported tripped	OLR acted.Reset done(2 times)	00:05:00	02:00:00	
5	OHP	CO-26	Reported tripped	OLR acted.Reset done	00:10:00	00:20:00	
6	OHP	CO-77	Reported tripped	OLR acted.Reset done	23:55:00	00:05:00	
7	OHP	WOBR on CO-25	Reported B/C not running	YARD interlock ZSS cage stuck up.Made free and tested okay	00:20:00	00:40:00	
8	OHP	TBS on CO-22	Reported LT and luffing not working	Control not made on.Made on and tested okay	23:55:00	00:10:00	
9	OHP	TBS on CO-22	Reported Lt not working	Wrong complaint	00:40:00	01:05:00	
10	CHP	CC 112 SCR-8	Reported LT not working	Wrong complaint	23:45:00	00:00:00	