



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/06/2025

Area: OHP

Equipment	Job
LOCP-1	Crushers,VF's motor and panel PPM done
LOSP-1	ALL motors and panel PPM done
CO-5,1A	Sump pump maintenance done
CO-5	P/C checking is going on
TBS ON CO-5A	Brake timer replaced and tested okay
BRC on CO-32	CT limit switch replacement done and tested okay
BRC-4 on CO-34	BW-1 ZSS rectified and kept in line
WOBR on CO-29,CO-29	PPM done