



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Co29	olr acted	Reset done	15:20:00	15:30:00	
2	OHP	WOBR on CO29	LT not working found mpcb trip due to material jamming , M2 break problem	Jam cleared and mechanical dept adjusted brake	18:00:00	18:40:00	
3	OHP	CO67	olr trip due to jamming at tail end	Reset done	15:05:00	15:20:00	
4	CHP	CC51	Motor tripped on olr 2 times	Reset done	17:40:00 20:17:00	17:45:00 20:20:00	
5	CHP	Cc51	Yard conveyor tripping over load acted 8 times	Reset done	16:35:00	16:40:00	05.10pm to 05.15pm:05.40pm to 5.45pm:6.55pm to 07.00pm:07.35pm to 07.40pm:08.15pm to 08.20pm:09.10pm to 9.15pm:09.40pm to 09.45pm
6	CHP	SCR5 on CC32	BC not running found chute sensor module problem( module shorted)	CJS bypassed in IO rake	16:00:00	16:30:00	
7	CHP	Cc107	Not running found chute sensor acted due to water	Probe cleaned then ok	15:30:00	16:00:00	
8	CHP	SCR9 on Cc104	*LT not working found PCRD OT acted. * Slew and BW not running found oil temp high and fan MCB tripped.	*Tension released then ok * Fan MCB made on.	16:30:00 21:00:00	16:50:00 21:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
9	CHP	SCr4 on CC33	LT not working found track jaming	Informed to operation	20:40:00	21:00:00	
10	WT	OP1	not moving found emergency operated condition at the time of coupling	Emergency released	14:30:00	14:40:00	Not an electrical complaint
11	WT	OT1	D1 tripped on pgf fault	Reset done	15:00:00	15:05:00	
12	WT	OT3	not moving found middle connector pad fallen problem after completion of rake	Power made off and fixed collector pad	20:00:00	20:10:00	
13	WT	OT4	Not rotating found Initial problem ( problem at remaining one wagon)	Adjusted sensor	21:00:00	21:05:00	
14	WT	OP1	Not moving found D6 motor tripped on olr (after tripling 3 wagon)	Reset done	21:20:00	21:35:00	
15	IOSA	OC13a	Conveyor is not healthy but after acknowledge it is healthy found pull card missing	Pull card bypassed then ok	20:20:00	21:05:00	