



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/01/2026

Area: CHP

| Equipment | Job |
|-------------------|---|
| Lighting Towers | Jungle cutting done for lighting rectification |
| LC 18,CM 17,18 | IO rack Prophi bus looping cables replaced with new loops |
| SCR 8,9,10 | 3nos 120W and 2 nos 200W LED fixtures provided |
| LC 17 | Transformer rooms cleaning done |
| All yard machines | PCRD inspection was done and rectified the defects |
| CC 114,115 | Panel side PPM was done |