



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/04/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO34	CT NOT TAKING PLACE WIRE LOOSE IN SELECTOR SWITCH	TIGHTED	19:00:00	19:20:00	
2	OHP	BRC ON CO28	B/W 1 NOT RUNNING OLR ACTED	RESET	19:30:00	19:40:00	
3	OHP	BRC ON CO 31	B/W1 AND B/W2 NOT RUNNING ZS HIGH MISSING	BY PASSED IN INTERLOCK PENAL	19:40:00	20:00:00	SUSPECTED IN FESTOON CABLE
4	CHP	CC 34 SCR2	LT NOT TAKING PLACE O/T ACTED	RELEASED	19:25:00	19:35:00	
5	CHP	CC 32 SCR 5	B/C ZS CAGE NUT BOLT MISSING	NEW NUT BOLT FIXING THAN OK	14:00:00	14:30:00	
6	CHP	cc 52	not moving, motor physically moving, fluid coupling o/p not run	informed operation and mechanical	19:15:00	20:10:00	not electrical delay
7	WT	cp1	NOT MOVING FWD, FWT LIMIT ACTED	RELEASED	15:10:00	15:20:00	
8	WT	OP1	sometimes stop not moving fwd, anticollision sensor malfunction	bypassed	21:30:00	21:45:00	to be checked in G shift